

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Water Recycling Treatment Site Log Book



Site Log books are an important record of our activities and could, in the event of a product quality or Health and Safety incident be used as legal evidence of our actions. It is therefore of the utmost importance that all visitors and actions taken must be recorded in the Site Log book.

Site Details:

Site Name	Foxton WCC
Site Short Code	EXTNST

Document Control:


Date of Issue	6/12/2024
---------------	-----------

Table of definitions:

SS	Suspended Solids mgl
NH ₃	Ammonia mgl
P	Phosphorus mgl
FE	Final Effluent
Flow l/s	Instantaneous flow l/s

Notes: This document should be printed double sided A4 landscape paper, spiral bound with a plastic front and back cover
The Water Recycling Site Log Book Re-order Form should be issued with this document (between pages 80 & 81)
Completed Site Log Books must be retained for 5 years

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
6/12/24	10:50	12:10		AW	Routines		
7/12	15:40	16:00		AW	Screen + compactor fault		
7/12	11:30	12:10		AW	REMAKE MIX 4-Phase FROM FEEDER		
09/12/24	13:30	13:30		DVS TAP	PCC DFI COMMS		
09/12/24	13:00	15:30		AW	Routines		
10/12/24	13:50	14:15		AW	Routines		
11/12/24	0700	1100		Barbake	Site		
12/12	10:00	14:00		AW	lunch + routines		
13/12	07:35	09:10		AW	Routines		
13/12	11:45	12:00		AW	Mobile FE monitor pick up		
14/12/24	15:05	15:55		AW	Desludge HSTA		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples				FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify
Storm overflow	38.62	Sunny	/	SC	20	0.51	0.61	2.00 10.3
reset all ok		Rain wind	/	SC	20	0.81		
	38	Dry	/	S/C	220	0.56		
knockdown PSTs, can PSTs to water PST 1+2 = 3.0m PST 3+4 = 3.0m	38.65	O-C	/	SC	15	0.55	0.40	2.01 9.7
PSTs can to water PST 3+4 = 3.0m	32.86	O-C	/	SC	20	0.63	0.49	1.85 10.2
knockdown PSTs, can PSTs to water PST 1+2 = 3.0m PST 3+4 = 3.0m	38	O-cast Damp	/	SC	20	0.55	0.63	2.30 10.0
knockdown PSTs, can PSTs to water, Storm overflow	37.65	O-cast wet	/	SC	20	0.30	0.43	1.39 10.2
			/	SC	15	0.62		
	36	Dry	/	VC	25	1.22	0.46	Fe = 0.144

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
16/12	11:45	15:30		AW	lunch + routines + chemical delivery		
17/12	10:28	17:53		W	Monitors + Chemical delivery		
18/12	08:50	10:45		AW	Routines		
18/12	10:45	11:15		JOS	Site Visit		
18/12	10:45	11:15		CLT	Site Visit		
18/12	10:45	11:15		JOS	Site Visit		
18/12	10:55	11:30		AW	Ben Spet FC + Canister		
19/12	07:45	09:30		AW	Routines		
19/12	14:40	15:30		W	1 x 2831R		
20/12	08:00	15:00		RAMPALL SURVEY	SITE SURVEY		
20/12	10:40	17:40		AW	Routines + lunch		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
knock-down PSTs. ran HSTs to loader.		sunny	/						
PST 1+2+3+4 = 3.0m no chemical delivery.	39.07			SC	25	1.18	0.49	2.24	
PST 1-4 3m HSTs unblended	16.97	0/c	/	SC	10	0.66	0.51	2.03	13.0
Found HSTs still deslagging	37.02	0-cast windy	/	SC	15	0.39	0.49	1.56	
	44.25	clear cold wet	✓	SC	20	0.25	0.46	2.40	10.3
PSTs @ 3.0m	38	sunny cold	/	SC	20	0.35	0.44	1.57	9.20

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant	
						Removed/Installed Details	Due Date for Return
21/12/24	8:40			AIN	De Sludge Hsts		
22/12/24	16:00	16:45		AIN	Routines		
27/12/24	08:00	12:00		PANDAL SURVEYS	SITE SURVEY		
24/12/24	08:19	11:03		AIN	Routines		
25/12	10:45	11:15		WRC	1x28 3/4		
26/12/24	13:05	15:05		AIN	OPS		
29/12	09:20	10:15		AIN	1x28 n ³ Spk		
30/12	11:30	15:00		AIN	lunch + Routines		
31/12	13:45	15:30		AIN	Routines + lunch		
1/1/25	13:40	15:30		AIN	Routines		
5/1/25	13:05	13:35		WRC	1x28 SPK - 4PC		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
Fsts 2.8m Psts 3m	36	overcast	—	VC	20	0.08	0.39	2.41	11
	36	Dark		VC	25	0.69	0.58	2.13	9.2
Unblocked HSTS, decided not Psts									
FST 9/8 2.8m Psts 3m	40	0/c	—	VC	15	0.29	0.45	2.07	11.0
Over an hour to unblock bellmouths with pump... most of filters blocked.	38	overcast	✓	VC	25	1.50	0.41	2.21	
	38.74	Sunny	—	VC	20	1.47	0.51	2.34	
	37.84	overcast windy	—	VC	20	1.79	0.50	1.88	
		Sunny cold	—	VC	25	1.64	0.33	2.11	

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant	
						Removed/Installed	Due Date for Return
7/1/25	15:30	15:30	[REDACTED]	AW	Wrench + Routines		
2/1/25	8:00	9:40		IOS	Union 4 Score		
8/1/25	08:20	9:40		INFATECH	Union Score		
8/1/25	08:00	9:40		Barhale	Union 4 Score		
—	08:00	9:40	[REDACTED]	WRATECH	— ✓		
8/1/25	15:00	16:10		AW 330	Storm pump routine work		
9/1/25	11:55	13:20		AW	Wrench + Routines		
10/1/25	11:40	12:15		AW	SITE VISIT		
10/1/25	12:00	15:00	[REDACTED]	AW	Impact assessment + Routines		
12/1/25	11:10	11:55		AW	Run bellmouths		
12/1	14:30	15:10		AW	1 X 28" SK		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					
				Visual Check	SS	NH ₃	P	Other Specify	FE Temp °C
BOTH HSTS SURCHARGED, PE POINT SURCHARGED - STORM PUMP SURCHARGED. GIVER WAS BURST ITS BENTS. PHOTOS TAKEN. WILL USE PUMP TO HELP KNOCK DOWN PSTS NEXT VISIT.	36.87	Sunny cold	/	SC	15	0.54	0.43	I 1.98	8.5c
RETIRED NEW PIPEWORK FOR STORM PUMP, RENOVATED STORM TANK DRIVE WHEEL AS FOUND RUINED	37.97	Sunny cold	/	VC	25	0.58	0.55	I 2.45	8.4c
Flow sensor reduced from 0.8 to 0.7 on both pumps		Sunny cold	/	VC	35	0.44	0.34	I 1.99	
	38.86	Sunny cold	/	VC	30	0.54	0.34	I 1.99	8.2c
HST on the right (from signing in building) dislodged to water. The other ~~dislodged~~ did not move.	36.8	Cold	/	VC	25	0.26	0.50	Fe = 2.68	9.0°

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
13/1/25	11:00	13:00		AW	Routines + lunch		
14/1/25	12:00	15:30		AW	Routines + lunch + e-learning		
15/1/25	09:35	15:30		AW	Routines + lunch		
16/1/25	11:22			AW	Went to Routines		
16/1/25	18:20	19:25		AW	Went to Routines		
17/1/25	12:00	13:30		AW 530	Customer report - power outage		
17/1/25	14:30	16:00		AW 530	DANCE SCHEDULE		
18/1/25	15:50	17:00		AW 530	Routines		
19/1/25	14:15	14:45		AW 530	DESIGN		
				AW 530	DESIGN		
				AW 530	DESIGN		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety, please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
20/1/25	8:00	9:20	[REDACTED]	AN	Routined		
20/1	10:00	10:30	[REDACTED]	HW	www		
21/1	10:20	11:00	[REDACTED]	HW			
21/1/25	12:44	14:00	[REDACTED]	HW	Robes + lunch		
21/1/25	07:30	11:30	[REDACTED]	HYDRO	Service inlet screen & compressor		
22/1/25	10:00	11:45	[REDACTED]	AN 330	STORM PUMP		
22/1	13:30	16:30	[REDACTED]	AN	Continues		
22/1/25	19:50	20:57	[REDACTED]	AN	INVESTIGATE POSSIBLE POLLUTION REPORTED BY EA		
23/1/25	09:32	15:50	[REDACTED]	AN	HA + ROWS		
23/1	10:40	11:15	[REDACTED]	AN	IA		
24/1/25	10:37	11:10	[REDACTED]	AN	IA		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
OTS HUMUS 20Lm Pels 3m + 3.5m 35.4	36	Dry	—	VC	25	0.20	0.50	Fe 2.46	9.6
	36	DS	—	VC	20	2.19	0.54	Fe 2.54	10.7
PERFECT BRUCE PHOTODU, CAPT MONITOR									
WIN-BLACK R/S/M NORMAN TANK WITH PUMP / TAP LPM NOT COMING OUT.	38.6	CLOUDY DARK	—	VC	30	1.17	0.17	1.33	8.2
PST'S SURCHARGED AND LEAKING THROUGH RETAINING WALL. OCM UPDATED + PCC COMPLETED WITH PHOTO'S.	36.62	DARK DRY	GATES OK	MF SC	25	0.78	0.69	0.64	10.3
IPA Completed, again addressed photos / PST surcharged, long leaks in concrete / photos uploads on PEC. JCS number 65598049 uploaded but its not loaded. This has been fixed / fixed JCS	38.71	0/Cld	—	MF VC	25	0.59	0.57	2.25	11.3
ALL IN HAND. SITE OPS HOUSE UPDATED THE P.T.									
Uploads photos to PEC	35.76	0/Cld	X	VC MF	25	0.66	0.27	2.27	11.5

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
24/1/25	11:20	12:10	[REDACTED]	AW	Routines + screen alarm		
24/01	1300	1800		AW	Chemical (P)		
25/01	1200	1400		AW	" "		
25/1	1600	16:30	[REDACTED]	AW	Desludge Humus		
24/1/25	13:30	14:30		AW	Routines		
24/1/25	12:45	14:10		AW	Routines + lunch		
27/1	13:00	14:20	[REDACTED]	AW	Pec		
29/01/25	18:00	22:45		AW	20 Nibble Rehabilitation		
30/1/25	12:27	14:00		AW	site visit		
"	"	1400	[REDACTED]	~~AW~~ EA	"		
30/01	1245	1300		AW	chem dosing		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples				FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify
	38.63	Sunny windy	✓	VC	25	1.11	0.80	2.68
Cleared pipework as Blocked in manifold and discharge pipe - blockage seen in the pipework, filter now not leaking revealing tomorrow was new manifold part								
Awaiting manifold fitting, discharge pipework also still blocked unable to clear								
No Sludge from normal one DTS 2.2m				VC	25	1.96	0.79	2.16 9.6
Humus 2.2m Pits 3.5m 3m 3m 3m Storm outfall chamber high. HETS surcharged	34			VC	25	1.48	0.70	2.84 9.3
	35	overcast rain	✓	VC	15	0.80		
	41	Dry	✓	VC	20	0.73	0.65	2.43 9.9
could not find FE Point to disinvest. Only off to a FE Point. Saw fire taken from higher. (E.C. Point) since from with in discharge a head. River a Ditcher high level in village is not part being from these water. with year 2011. 2012 to be E.C. point for RR R/S. p.s. C.C. point		Dry	✓					
Drop pipework off for								

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
30/1/25	13:20	16:00		AW350	FF47H pump, per work		
31/1/25	12:05	14:15		AW	IA + Routines + lunch		
31/1/25	12	13:20		RADIAN SUBS	Subs		
31/1/25		13:15		AW	Permit to work		
31/2/25	06:30	07:10		WLA	1x28 SR		
31/2/25	13:15	14:30		AW	Lunch + Routines		
31/2/25	13:15			AW	Storm Tank Clean		
4/2/25	07:45	10:30		AW	Routines		
4/2/25	08:00			AW350	EMERGENCY SHOWFA		
4/2/25	09:45	10:30		AW	MEET MR WICKS		
4/2/25	10:05	10:30		M-n-wick	Site		

Comments

Comments

RECEIVED IN RETURN RATE LOW, RATED POOR WERE
AND (K99 24 NUTU, BEST WERE

Find HST 2 tunnel off. designe both HSTS

Steam discharge chamber high, at point backed up

This template is available on Hawk

You are reminded that Site Log Books are official documents and comments must be restricted to operational performance. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant	
						Removed/Installed	Due Date for Return
4/1/25	09:00	11:00	[REDACTED]	AW	Emergency Sewer Pipework.		
5/2/25	12:10	14:15	[REDACTED]	AW	Lunch Routines		
06/02	17:00	18:30	[REDACTED]	AW	EDM Alarm		
07/02	8:45	15:00	[REDACTED]	MR. WILK	Leak		
7/2/25	12:35	15:00	[REDACTED]	AW	Lunch Routines		
8/2	15:30	16:30	[REDACTED]	AW	Desewage Yards.		
9/2	17:55	14:30	[REDACTED]	WBL (NTH)	Rubbish collection		
9/2	14:55		[REDACTED]	AW	Routines + Lunch		
10/2/25	10:35	13:00	[REDACTED]	AW	Routines + Lunch		
11/02	11:20	13:10	[REDACTED]	AW	Accident Investigation		
11/02	11:40	12:07	[REDACTED]	AW			

Comments

This template is available on Hawk Template revision date: April 2014

You are reminded that Site Log Books are official documents and comments must be restricted to operational information. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant	
						Removed/Installed	Due Date for Return
11/2/25	12:50	14:00	[REDACTED]	QUARTER elec	Vegetation JLT		
12/2/25	09:25	11:00	[REDACTED]	Access	Site visit		
12/6/25	10:25	11:15	[REDACTED]	AWSTIA	PLC DEL Error + OLS Low Batt		
12/12/25	11:20	11:30	[REDACTED]	AW	OSM		
13/6/25	08:00	10:00	[REDACTED]	AW	Routines		
15/6/25	18:15		[REDACTED]	AW	Routines		
15/6/25	13:15	14:15	[REDACTED]	AW	Routines		
16/6/25	15:05		[REDACTED]	AW	Routines sample only		
17/2	13:40	14:55	[REDACTED]	AW	Routines		
19/2/25	12:15	14:00	[REDACTED]	AW	OPS		
20/2/25	09:00	10:30	[REDACTED]	AW	OPS		

Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
Serial port on PLC reset + alarm cleared on 17/04.									
Desludged all PSTs, Balance Tank (night) and HSTs. 4STs - 2.2m 3FTs all clear. Sludge - 99% (chemical = 52%) Site taking in more than FFT. All forms submitted.	39	DA/cold	—	VC	30	0.24	0.44	Fe = 1.72	6.60
reduced dose rate from 7.0 to 5.0									
dose rate = 7.0	38	Sunny	—	VC	25	2.02	0.57	2.20	8.12
Reduced dose rate to 5.0 from 7.0, As per A. Fuller.	38	cold	—	VC	25	2.23	0.70	—	—
Unable to fully desludge HST to left as too thick, had pump running for 45mins.	37	Sunny	—	VC	20	2.11	0.66	2.73	9.3
Full desludge on HSTs, broke to water with pump.	20	DRY	✓	VC	30	1.28	0.65	2.41	8.3
	37	Overcast Damp	✓	VC	25	0.22	0.66	2.26	11

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
21/2/15	12:30	13:50	[REDACTED]	AW	Routines		
23/2/15	12:50	13:50		WROL	1x 28" S/R + 1x 40" S/R		
23/2/15	18:25	19:10		AW	Deslodge	150504	
24/2/15	08:05	08:50	[REDACTED]	WROL	1x 28" S/R		
24/2/15	11:30	13:20		AW	OPS		
24/2/15	06:00	07:30		WHS TFA	plc comms		
25/2/15	10:50	12:50		AW	Routines + call check + lunch		
26/2/15	09:05	10:35		AW	Routines		
26/2/15	18:40	19:30	[REDACTED]	AW	Loss Pollution		
"	"	"		AW	"		
27/2/15	10:15	10:35		AW	Loss Pollution FP		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					
				Visual Check	SS	NH ₃	P	Other Specify	FE Temp °C
desludge HSTs to water, clean w/w filter & replace BST1=3.0 BST2=3.0 BST3=3.0 BST4=3.0	38	Sunny windy	✓	VC	25	1.54	0.77	I 2.29	10.7
Desludged both HST to water.	36	Dark	✓	VC	30	2.30	0.82	Fe = 2.64	10.40
	37	Damp overcast	✓	VC	30	0.97	0.68	I 2.30	14.3
	39	Sunny Damp	✓	VC	20	0.56	0.58	I 2.29	11.2
	38	overcast rain	✓	VC	25	0.36	0.81	I 2.26	8.40
Go to Fe water									

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	Due Date for Return
27/6/13	1100	1815	[REDACTED]	AW	Routines / 100m ±A.		
27/6/13	1400	1515		AW	IA + Routines		
27/6/13	1450	1515		AWS	EA actions		
28/6/13	1020	1030		AW	Pick up Pump		
28/6/13	1110	1135		WRCL	1x28 S/R		
28/6/13	1115	1215		AW	Bellmouth's dropped		
2/3/13	0950	1045		WRCL	1x28 S/R		
2/10/13		1710		AW	Routines		
3/3/13	0745	0915		AW	Routines + meet setter	10 Setter turned off	
4/3/13	0745	0900		AW	Routines + meet setter		
4/3/13	1200	1500		WRCL	CLEAN PST		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
Good Passel Sand available Pond - filling up	38	Sunny	/	—	—	no sample	—	—	—
(Pollution) no Pollution found Tank 1 loading where pipe goes on has a hole so pipes are being to load	27	Sunny	✓	25	VC	0.11	0.64	263	9.2
AS Hums 2.2m Psts 3m deswage HSTS. HST 1 = 2.5m HST 2 = 2.2m Chemical = 40 PST 1 = 3.0 PST 2 = 3.0 PST 3 = 3.0 PST 4 = 3.0 no settler PST 5 am 3.0m	21 38 38	Sunny Sunny cold Sunny cold	✓ ✓	25 28 26	VC VC VC	1.37 0.79 0.32 0.31	24 2.47 1.97	105 8.2 8.2	


You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
5/3/25	07:30	09:15		AW	Routines + meet setter		
5/3/25	10:00	15:15		WROL	WARR AS DIRECTED		
5/3/25	15:00	15:30		AW	Site		
6/3/25	07:45	16:45		AW330	PST works		
6/3/25	09:00	13:30		AW	Routines + meet MTE + lunch		
7/3/25	10:30	15:00		AW	Routines + other actions + lunch		
9/3/25	07:45	15:00		WROL	PST - WORK AS DIRECTED		
10/3/25	11:10	13:15		AW	Routines + dosing 22 Samuels lunch		
10/3/25	13:00	14:30		AW330	Site meeting		
10/3/25	13:02	14:22		EA	INSPECTION		
10/3/25	13:10	14:30		AW	EA VISIT		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
PSTS @ 3.0M		SUNNY cold	✓	MF VC	25	0.32	0.90	I 1.87	8.4c
Temp repairs made to PST work!									
	38	SUNNY	✓	VC	25	0.79	0.67	I 1.79	10.4c
	37	SUNNY warm	✓	VC	20	0.54	0.66	I 2.02	
has Complete .									
reset pump	39.47	0-cast	✓	VC	25	1.74	0.87	I 2.18	10.6c



 You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant	
						Removed/Installed	Due Date for Return
11/3/25	13:15	13:45		AW	Routines		
12/3/25	07:00	07:00		IOS	Humus tower		
12/03/25	07:00	14:30		IOS	Site		
12/3/25	10:30	12:30		AW	Routines + sm + lunch		
12/3/25	10:30	10:45		AW	Ritoto's of food forward		
12/3	13:45	14:45		MR. Wicks	Site		
13/3/25	09:10	10:05		AW	ops		
13/3/25	9:30	11:30		HBC-	Site R-4 DIS		
13/3/25	10:30	11:30		AW	moor from behind		
14/3/25	12:50	14:20		AW	lunch + Routines		
14/3/25	5:00	7:40		WROR	2x 285R		

This template is available on Hawk Template revision date: April 2014

Page 29 of 101


You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
17/03/25	10:35	11:50		AW	Routines		
17/3/25	11:30	16:00		Hypco	Service Inlet Screen / Compact.		
18/3/25	12:10	14:20		AW	Routines + lunch		
19/3/25	08:40	08:45		AW	Routines		
19/3/25	09:45	11:25		AW	Routines + comp check		
19/3	10:40	11:06		AW	OSM		
19/3	10:40	11:04		EA	OSM inspection.		
19/3	10:40	11:04					
20/3	10:55	11:40		AW	Routines + alarm		
21/3/25	09:45	11:00		AW	comp check + Routines + alarm		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
25th - 3.0 All desludged. 45th - 2.1 1 wouldn't desludge, can't find pump. 2 desludges. Tried feeding but nothing.	40	Damp	/	VC	35	0.80	0.57	Fe = 1.06	11.50
	38	SUNNY	/	VC	30	3.35	1.00	2.29	10.2
	41	SUNNY	✓	VC	25	0.74	0.74	2.27	10.5
300 raised for dosing P2, killed twice in 2 weeks									
reset dosing P2. P1 won't run in flow control, P1 eventually in fixed dose. P2 line P2SS blocked. CONR check for tomorrow	39 38	SUNNY O-cast	✓ /	VC VC	25 30	1.55 0.74	0.98 1.12	2.49 2.86	11.3 10.8

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.


Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
21/3/25	11:20			Ans 350	Dosing.		
21/3/25	11:20	13:00		Ans	Site visit		
21/3/25	11:20	13:00		IOS	Site visit		
21/3/25	11:30	13:00		IOS	S.K. visit		
21/3	12:00	13:30		AW	Site + Lunch		
21/3/25	12:00	15:30		AW	Dosing Pump		
21/3/25	16:55	17:30		AW	Dosimeter		
22/3/25	13:10	14:15		AW	Routine		
22/3/25	22:05	22:45		AW	EDM - LOGIC R EDM CALCULATION, AARON.		

100

This template is available on Hawk Template revision date: April 2014

Page 33 of 101

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
23/03/15	11:25	13:40		AW	Routines		
24/3/15	10:10	12:45		AW	Routines + alarm + lunch		
25/3/15	13:40	15:30		AW	Routines + alarm		
26/3/15	09:50	08:20		AW	comb check		
26/3/15	11:40	12:45		AW	Routines		
26/03/15	23:39	01:40		AW	EDM - logic EDM Calculation		
27-3-15	10:10	10:20		AW	UWATR		
28/3/15	12:00	19:30		AW	Lunch + Routines		
22/03	12:45	15:00		AW	Site Tidy up		
27/3/15	13:00	15:30		AW	Stann Routines Tinner		

are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
Knock down PSTs, chemical order due week 31st	40	O/C	—	VC	25	0.99	6.84	2.88	11.1
Knock down PSTs, both STTS are full. Cleared PST wash water hoses. Email sent to [REDACTED] regarding EDM alarm, I'm aware of alarm	38	O-cast	✓	VC	30	0.68	0.66	2.06	10.4
	37.62	O-cast	—	VC	30	3.88	0.98	2.08	11.6
	35.89	cloudy	—	VC	25	1.07	0.88	2.34	11.3
	38	Sunny	✓	VC	25	1.87	0.86	2.54	11.6
Storm return pump running when FE flows over AT L/S causing Storm return to discharge due to too much flow, turned boom off, left 15-20 minutes, checked @ 5 mins + flow now 37 L/S and Storm return no longer discharging. Will raise an urgent JCB for next day to change piece meters of Storm return pumps, stopping them from coming on during high flows. Don informed A Supply to leave both Storm return pumps off, when receive site clearance from Management updating Station, JCB raised for further investigations	44	Drizzle	X	VC	30	1.61	0.78	2.43	11.3
	38	Sunny	—	VC	30	2.98	1.02	2.63	

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
28/3/15	07:40	09:30	[REDACTED]	AW	Routines		
28/3/15	12:20	12:35	[REDACTED]	AW	ULWTR		
28/3/15	16:15	16:45	[REDACTED]	AW	DESLODGE		
30/3/15	10:45		[REDACTED]	AW	ROUTINES - LEAD CALCULATION		
31/3/15	12:15	14:00	[REDACTED]	AW	Lunch + Routines		
31/3/15	18:50	19:20	[REDACTED]	AW 330	CONCRETE		
1/4/15	07:45	09:25	[REDACTED]	AW	CONCRETE + Routines		
2/4/15	07:30	09:25	[REDACTED]	AW	CONCRETE + Routines		
2/4	8:00	10:30	[REDACTED]	103	FOR FLAMMABLE SOLID		
02/04/15	18:15	20:05	[REDACTED]	AW	Site Check		
3/4/15	08:00		[REDACTED]	AW	CONCRETE + Routines + CONCRETE		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples				FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify
check down RSTS.	35	0-cast	✓	VC	25	0.74	0.73	I 2.30
STIE DOING FRT + ABOVE - STORM TANK FLOW AND OVER FLOWING STORM O/R NH ₃ = 17.8	37	—	—	VC	25	2.75	0.84	RR 2.77
	39	DRY	—	VC	20	0.47	0.68	FR 2.48
USER on OLE.	37	SUNNY	—	VC	25	2.90	0.92	I 2.80
Storm discharging. Storm NH ₃ = 16.95, combined NH ₃ = 2.97 petaken to base								
P1 drop = 55ml/m P2 drop = 35ml/m, email sent to PM, scientist and scientist regarding issues and results from interstage samples	34	cloudy	—	VC	40	0.89	0.68	I 2.59
	32	SUNNY	—	VC	30	0.84	0.84	I
Outfall: NH ₃ = 0.00 P = 0.13 Fe = 0.00 SS = 0.00 T = 12.80 DTS: PST1 + 2 + 4 = 3.0 PST3 = 3.1 HST1 + 2 = 2.2 Sludge Tank = 70% ST below ground 1.907 2.09% D4 informed compliance check raised for tomorrow.	37	Dry	—	VC	40	1.29	1.04	Fe = 4.10
								13.30

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant	
						Removed/Installed	Due Date for Return
3/4/25	08:00	11:00	[REDACTED]	AW	comp check + Routines + chemical delivery		
3/4/25	14:58	17:00	[REDACTED]	Biomarsh	C250743		
3/4/25	15:10	17:00	[REDACTED]	Biomarsh	C250743		
3/4/25	18:50	21:00	[REDACTED]	Biomarsh	C250743		
4/4/25	09:15	DAY SHIFT	[REDACTED]	Biomarsh	C250746		
4/4/25	07:40	09:30	[REDACTED]	AW	Routines		
4/4/25	08:15	DAY SHIFT	[REDACTED]	Biomarsh	TANKER EMPTY STORM TANK		
4/5/25	11:00	11:10	[REDACTED]	AW	Site		
4/5/25	16:20	21:00	[REDACTED]	Biomarsh	C250743 / C250746		
5/5/25	06:39	8:20	[REDACTED]	Biomarsh	C250746		
5/5/25	06:45	DAY SHIFT	[REDACTED]	Biomarsh	C250743		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

[illegible]

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
05/04	10:30	12:00		AW	DESUDGE HSTS + CAP CHECK		
05/04	14:15	12:40		AW	SAMPLE		
5/4	9:00	N/S		Biomarsh	C250743		
5/4/25	07:00	D/S		-11-	C250743		
6/4/25	07:25	D/S		Biomarsh	C250746		
06/04	10:25	11:20		AW	ROUTING		
06/04	18:25	N/S		Biomarsh	MAINTAIN STORM TANK		
6/4/25	18:30	N/S		Biomarsh	11		
7/4/25	07:23	D/S		Biomarsh	C250746		
7/4/25	07:24	D/S		Biomarsh	C250743		
7/4/25	09:10	09:20		AW	OSM		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					
				Visual Check	SS	NH ₃	P	Other Specify	FE Temp °C
	34	Dr	—	VC	30	0.68	0.76	Fe 2.47	12.2
OSTS = 3.2m HSTS = 2.0m Sludge = 58% Chemicals = 89%	36.05	Dr	—	VC	25	0.55	0.72	Fe 1.51	12.1

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

			Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
7/4	0900	1230		10's	UNION VISIT		
7/4	0900	0930		WREL	1 x 28 5/2		
7/4	1130	1430		AW	Coner + Routines		
8/4	0745			AW	conclcheck + Routines		
							
							
8/4	1400	1533		AW	Site visit		
8/4/25	1600	1533		AW	Site visit EA		
8/4/25	1410	1533		~~EA~~	Incident response		
9/4/25	0740	1135		AW	conclcheck + Routines		
9/4	930	1345		AW	Site visit		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
interstage samples email sent	39	Sunny	/	VC	40	2.33	1.30	I	
interstage samples HST1 P=1.02 I=3.48. HST2 P=1.11 I=3.30		Sunny	/	VC	40	0.67	1.24	I	10.5
BF1 NO sample BF2 P=2.58 I=7.17 BF3 P=2.01 I=6.39	32								
BF4 P=1.17 I=6.18 Siphon chamber P=0.63 I=3.42									
filters combined P=1.32 I=3.63									
SHT1=41% SHT2=50% chemical 59% P51-4=30%									
		Sunny	/	VC	40	3.77	1.14	I	
	32	Overcast	/	VC	40	0.74	1.10	I	

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
8/29	11:30		[Redacted]	AW	S.G.		
9/4/25	11:40	14:20		AW	3rd follow up + 3 remove ground cover open valves + close. Rock feed lines		
9/4/25	14:30	15:30		AW	Site		
9/4/25	18:35	19:30		AW	SITE CHECK		
10/4/25	09:30	09:30		AW	Routines		
10/4/25	05:40	12:15		A	Site Admin.		
10/4/25	09:50	14:30		Tivoli	Grounds		
10/4/25	09:50	14:30		Tivoli	Grounds		
10/4/25	09:45	12:10		A.W	EPP		
10/4	10:30	10:50		AW	ERP + Routines		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
				VC 440	1.02	1.20	2.22	fer	
		sumy	/	VC	40	5.19	1.42	2.62	
	33	/	/	MF	25	1.67	1.38	2.4	13.4
		o-cast	/						
		o-cast	/	VC	40	0.55	1.25	2.80	

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
10/4	11:30	13:55		AW	EPL + Routines		
10/04	1300	1400		AW	Chem mixing Pump		
10/4/25	14:40	15:50		AW	Maintenance		
11/4/25	0630			WREZ	BURNING TANK SKIN		
11/4	07:40	11:10		AW	coil check + Routines + meet settler		
11/04	1000	1130		AW	Chem mixing Pump		
11/04/25	14:00	15:45		AW	scope Sample Pails for B.C.		
12/4/25	0720	0745		WREZ	1 x 2800 S12		
12/14/25	9:30	10:00		BIONARSH	STORM TANK 1 x 1903 C251083		
12/4/25	10:40	11:40		AW	Comp check + Run bellmouths.		
13-4/25	06:50	04:50		BIONARSH	1 x 1903 STORM TANK C251083		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.



Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					
				Visual Check	SS	NH ₃	P	Other Specify	FE Temp °C
		0-rst							
pump w/s. collecting pump will return tomorrow to install.									
SST 08 DSS ML 100 ML.									
~~Flow~~ collect ML next visit									
inlet Stream 2 = 19.02 l/s Stream 2 = 19.53 l/s Settled P = 1.50 I = 4.7 Filters = P = 1.50 I = 3.34 Pump collected and installed. ops aware.	32	Sunny	✓	MF	10	0.70	0.53	0.64	
		Sunny	✓						
	34.80	Sunny	✓	MF SC	10	0.76	0.73	0.97	12.1

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
13/4	11:00	12:20		WRM	1228 S/R Storm tank very thick 75 min to load		
13/4	12:30	13:00		AW	lunch		
13/4/25	13:00	13:45		WRM	1x2889K		
13/4	18:35	19:50		AW	comp check + routines		
14/4	07:55	08:55		BLMARS4	TANKER STORM TANK C254083	1x10894	
14/4	07:55	09:45		AW	Routines + comp check + SAAA		
14/4	7:55	15:04		IOS	Spary		
14/4	7:55	12:00		SELECT Servers	---		
14/4	7:55	12:00		---	---		
14/4	8:00	12:00		---	---		
14/4/25	12:20	12:30		AZ	Pilot Runway Safety - SITE - C2024		

[illegible]

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
14/4/25	13:00	14:00		Tog Securo	Selwood Scope		
15/4/25	07:45	12:30		AW	complect + Routines + Filter Flush		
15/4	08:00	08:30		Waver	Went to site		
15/4	08:55	08:20		BIO MARSH	LOADS FROM STORM TANK		
15/4	01:00	01:30		Lenes	Maintain		
15/4/25	10:00	12:00		CANES	Audit tankers X3		
15/4/25	08:00	DAY		CANES	MAINTAIN		
15/4/25	07:30	DAY		LANET	ON SITE WORK		
15/4/25	19:00	21:00		DEB	COMP CHECK		
15/4/25	19:00	21:00			STEAM OFF IN OPERATION		
16/4	09:15	10:20		M/R, Wickes	look at Job Grit		
16/4/25	09:45	13:30		AW	complect + Routines + meet Wickes + EGM alarm + lunch + Inter Stage Sample		

W

This template is available on Hawk

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and safety. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant	
						Removed/Installed	Due Date for Return
16/04/25	13:30	14:00	[REDACTED]	BIOMARSH	LOAD STORM TANK C251083		
17/04/25	07:30	08:15		LANES	ON SITE		
17/04/25	07:45	10:20		AW	COMP CHECK + ROUTINES		
17/04/25	08:00	08:45	[REDACTED]	LANES	C251139		
17/04/25	07:00	07:45		LANES	—		
17/04/25	07:00	07:45		LANES	—		
17/04/25	05:30	06:15	[REDACTED]	LANES	ON SITE		
17/04/25	08:25	09:15		BIOMARSH	LOAD STORM TANK C251083		
17/04/25	08:40	09:20		BIOMARSH	PLC OFI GROW		
17/04/25	17:50	18:15	[REDACTED]	AW	SITE VISIT		
17/04/25	14:15	14:45		AW	COMP CHECK + OPS		
18/04/25	07:15	09:20		BIOMARSH	LOAD STORM TANK		
19/04/25	08:00						

Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C	
				Visual Check	SS	NH ₃	P	Other Specify		
	35.5	Sunny	✓	SC MF	10	0.30	1.10	I	1.50	
	40.5		✓	MF	15	1.43	1.18	P	I	
	27.63	cloudy	✓	MF VC	10	0.44	0.82	P	I	


You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
10/21/9.00	10.00		[REDACTED]	MDWIM	MOVE IBC.		
18/4/25 14:00	14:30		[REDACTED]	AW	Site check		
19/4/25 07:50	08:40		[REDACTED]	BiomassH	1x 19000 Storm tank.		
19/4 18.20			[REDACTED]	AW	Site check		
20/4/25 07:40	08:30		[REDACTED]	BiomassH	1x 19000 Storm tank		
20/4 12.30	13.15		[REDACTED]	AW	Site check.		
21/4 08.00	08:35		[REDACTED]	BiomassH	1x 19000 Storm tank		
21/4 12.15	1.35		[REDACTED]	AW	Routine		
21/4/25 09:30	14.00		[REDACTED]	AW	PST - Socot.		
22/4/25 07:48	08:35		[REDACTED]	BiomassH	1x 19000 Storm tank		
22/4	12.30	13.10	[REDACTED]	Wleat	1x 28 S/R		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
Chemical been swapped and dosing ok.	36	overcast	✓	VC	20	1.49	1.32	1.66	13
CAREER DOWNS HUMS DESUBBED	34	DRY		VC	20	2.11	0.98	0.83	
CAREER DOWNS HUMS DESUBBED		DRY		VC	30	1.25	1.00	0.66	
Pts In Hums 2.1m DeJugged.	33	wet	✓	VC	30	1.94	1.38	1.30	12.7

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
22/4/25	13:00	14:30		AW	Routines		
22/4/25	16:20	17:00		AW	SOS		
23/4/25	08:20	09:50		AW	OPS		
23/4/25	08:30	10:00		Biomars	1 COAD STORM TANK		
24/4/25	08:58	10:20		Biomars	2251083 1 x 190000 2 10RM 10NLC		
24/4/25	09:20	15:00		N. Wicks	Site		
24/4/25	13:19	17:10		AW	Routines + facilities		
25/4/25	08:39	10:30		Biomars	1 COAD STORM TANK		
25/04	08:45	09:30		AW	PST 2 Desum Valve + Spec mixing Compressor		
25/4	11:10	13:00		AW	Routines + comp check		
							

These are official documents and comments must be restricted to operational information and actions. Please contact your Line Manager as soon as you can. If you are concerned about any aspect of site performance or safety

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
Full desludge, everything dosing.	36.79	SUNNY	✓	MF SC	25	2.83	P 1.36	I 1.78	
	36.71	WET DRIZZLE	✓	MF SC	20	0.35	P 1.58	I 1.02	12.8
Desludged all PSTs + HST + balance tanks. Cleared Pigs from Sump Pump. Shunned PSTs 1, 3, 14. Shimmer Valve Seized for PST 7, fixed JCB. Collected HSTs + Pigs. Comp Check for next day. Do not lift + Dismt. Some Pigs. 37.91 D3									
Valve's All OK, spoken to A-hive with order a better chopper pump for time being, with speak to inst / Am about compressor set up size secure.			✓	MF SC	20	2.99	P 1.64	I 2.04	14.2
	36	0-cast	✓	MF SC	20	1.37	P 1.52	I 2.04	
	36	0-cast	✓	MF SC	20	1.37	P 1.52	I 2.04	



You are reminded that Site Log Books are official documents and comments must be restricted to operational information...
 Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant	
						Removed/Installed	Due Date for Return
25/4	20:15	20:45	[REDACTED]	AW	EA report Pollution <u>Stoem</u>		
26/4	08:22	09:30	[REDACTED]	Biomat	1 x 193 C251083 <u>Stoem</u>		
26/4	09:44	10:50	[REDACTED]	AW	comp check + HSTS		
26/4	13:55	14:40	[REDACTED]	AW	comp check + OPS		
27/4	25:07:35	09:15	[REDACTED]	Biomat	1 x 193 C251083 <u>Stoem</u>		
27/4	08:30	11:30	[REDACTED]	WOL	1 x 28 S/D		
27/4	11:17	12:00	[REDACTED]	Biomat	1 x 193 C251083 <u>Stoem</u>		
28/4	08:26	12:30	[REDACTED]	AW	SITE VISIT		
28/4	09:00	10:20	[REDACTED]	AW	comp check + alarm + routines		
28/4	09:30	11:15	[REDACTED]	Biomat	1 x 193 C251083		
29/4	09:35	10:25	[REDACTED]				

This template is available on Hawk Template revision date: April 2014

Page 59 of 101

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
29/4	13:50	15:10		AW	Routines		
30/4	06:50	09:40		BIOMARSH	C251083 STORM TANK		
30/4	07:30	10:30		AW	Routines + comb check		
30.4	08:15	11:15		AW	SITE CHECK + ASSIST + TEAMS MEET (5 AM)		
30.04	09:30	10:30		AW	chem mixing pump.		
30/04/25	13:35	13:55		Biomarsh	1 x 19 m ³ S/R C251854		
01/05/25	06:50			BIOMARSH	C251943 STORM TANK		
15/24	12:00	13:20		AW	comb check + Routines		
15/24	16:55	20:00		AW	interstage samples + meet tankers		
1/5/24	19:28	AUNIGHT		Biomarsh	C251960		
1/05/25	19:28			Wla	C251960		

please contact your Line Manager as soon as you can. If you are concerned that you are overworked or overburdened, please contact your Line Manager as soon as you can. If you are concerned that you are overworked or overburdened, please contact your Line Manager as soon as you can. If you are concerned that you are overworked or overburdened, please contact your Line Manager as soon as you can.

[illegible]

Reason for Visit		Equipment & Plant Removed/Installed	Date	for

You are reminded that Site Log Books are official documents and comments must be restricted to operational information or safety related information only.

Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant	
						Removed/Installed	Due Date for Return
2/5/25	0645	1050	[REDACTED]	AWS	site visit		
2/5/25	7:45	0801	[REDACTED]	BIONARSA	C251753		
2-5-25	745	SH/FT	[REDACTED]	BIONARSA	C251974		
2/5/25	0800	11:10	[REDACTED]	AWS	Routines + comp check, site issues		
2/5/25	0800	10:30	[REDACTED]	AWS	SITE VISIT		
2/5/25	08:20	11:00	[REDACTED]	[REDACTED]	Sample		
2/5/25	1000		[REDACTED]	MR WICE'S	magnasol delivery		
2/5/25	1025	11:30	[REDACTED]	AWS	dams + pm sample + lunch		
2/5/25	11:10	15:00	[REDACTED]	BIONARSA	C251083 974		
2/5/25	1940	N/S	[REDACTED]	BIONARSA	C251960		
2/5/25	18:40	18:47	[REDACTED]	-11-	C251753		
3/5/25	0730	D/S	[REDACTED]				

[illegible]




You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
03/05/25	7:30		[REDACTED]	Biomarsh	C251974		
03/05/25	07:55	08:55	[REDACTED]	AW	Site check + Routine		
03/05/25	15:50	17:00	[REDACTED]	AW	Alarm - BF1 Rotation Failed		
5/5/25	1830	night shift	[REDACTED]	Bio	C251960 C251974		
09/05/25	21:15	21:30	[REDACTED]	AW	Compliance Check		
4/05/25	06:47	07:30	[REDACTED]	Biomarsh	C251753		
4/5/25	6645	Day Shift	[REDACTED]	Biomarsh	C251974		
4/5/25	7:10	Day Shift	[REDACTED]	Biomarsh	C251960		
04/05/25	08:35	09:25	[REDACTED]	AW	Routine		
4/5/25	1820	night shift	[REDACTED]	Biomarsh	C251960		
04/05/25	18:40	19:10	[REDACTED]	AW	Alarm - BF1 Rotation Failed		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
Desludged HSTs. HST1-2.2 HST2-2.2									
Desludged PSTs+ BT. PST1-3.5 PST2-3.0 PST3-3.0 PST4-3.1	31.09	Dry	/	MF	10	0.99	1.26	Fe= 0.73	13.6°
All BEs rotating. Alarm handler says alarm is in but showing it is rotating. Have notified the DM. The site is turning the same as this morning. DTS are similar, BEs rotating and clear, obsing after BEs in fine. Only a bit of chunt from PSTs went over, possibly affecting sample temperature. Compliance checked by raised for letter on.	32.21	Dry	/	MF	35	3.09	1.26	Fe= 1.10	14.5°
	34	Dark	/	MF	20	2.11	0.68	Fe= 2.20	13.90
PST1-3.3 PST2-3.3 PST3-3.3 PST4-3.0 HST1-2.1 HST2-2.2									
Desludged both HSTs. Have not desludged PSTs manually. Above ground spill at 46%. Dosing after BEs over is fine. BEs rotating and clear.	19	Dry	/	MF	10	0.99	1.18	Fe= 0.34	13.6°
Site turning fine, same as in the morning. All BEs rotating. Agreed with (DM) to check site in the morning as sample keeps fluctuating during the day.	30	Dry	/	MF/W	40	3.66	2.22	Fe= 1.28	12.80

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
4-5 25	18:45	NIGHT SHIFT		BIOMARSH	C251974		
5/5/25	7:00	Day Shift		Biomaesh	C251960		
5/5/25	7:20	Day Shift		BIOMARSH	C251753		
5/5/25	07:00			BIO	C251974		
5/5/25	10:10	11:40		AW	OPS + COMP CHECK		
5/5/25	18:20	NIGHT SHIFT		BIOMARSH	C251974 C251960		
06/05/25	6:30	DAY SHIFT		BIOMARSH	C251974		
06/05/25	7:03	Day Shift		Biomaesh	C251960		
6/5/25	8:30	10:15		aw	SIDS		
6/5/25	8:50			BIOMARSH	C251974		
6/5/25	18:25	NIGHT SHIFT		BIO	C251960 C251974		
6/5/25	18:40						

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
	29	DRY	✓	SC	10	0.85	1.14	P F 0.55	12.7
	29.35	DRY SUN	✓	SC MF	10	1.00	1.16	P F 0.22	11.3

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
02/05/15 07:00	07:00	DAY SHIFT		DIOMARETHI	C251 974		
7/5/15 07:30	07:30	DAY SHIFT		General	C251 960		
07/05/15 07:20	07:20			DIOMARETHI	C251 453		
7/5/25 14:00	14:00	14:30		EuM	612 Sludge		
7/5/15 15:00	15:00	16:30		AW	Routines		
8/5/25 7:45	7:45	8:30		AW	SHF coupling		
8/5/15 09:50	09:50	12:45		AW	Routines + comp check		
8.5.25 11:40	11:40	12:45		AW	Leak		
8.5.25 12:20	12:20	15:25		AW	Clean Site i.		
8/5/25 16:00	16:00	17:00		AW	SHF coupling		
9/5/15 09:35	09:35	11:00		AW	Routines + comp check		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
9/5/25	13:40	15:20		ANUS	SITE VISIT		
9/5/25	13:40			ANUS	RSU		
9/5/25	14:00			REMOVED	SITE VISIT		
9-5-25	10:25	12:05		WELDON	1 x RSU S/R		
10/5/25	10:15	11:20		AN	Comp Check (Bellmouths)		
10/5	1930	NIGHT SHIFT		Blomash	C 252415		
10/5	1930	N/S		Blomash	C 252413		
10/5/25	22:40	NIGHT SHIFT		LINES	C252416 TANKER AS DIRECTED BY O.P.		
10/05/25	23:35	02:45		AW	Assist Tankers		
10/05/05	00:02	02:55		CSD	Jetting		
10/05/05	00:02	02:55		CSD	DETILING		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
Cable iron 0-20m/l, 1st stop iron 0-7m/l, 7th stop iron 1-72m/l								Iron 1-5	
	17	Dry	—	VC MF	15	0.70	2.16	0.44	13.9
	28	Dark	—	SC	0	1.57	1.95	Fe= 0.45	15.0°

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
11/5	10:25	10:33		AW	OSM		
11/5	10:15	11:15		AW	Site Check		
11/5/25	14:15	14:45		WROL	1 x 28 5/2		
12/5	08:50			AW	Routines + alarms		
12/5	19:30	20:00		AW	Filter failure		
13/5/25	07:47	08:20		AW	Chemical delivery		
13.5.25	07:45	10:25		AW	BF SENSOR / BIT		
13/5/25	05:40	10:05		AW	Site Visit - (MFX4)		
13/5/25	09:00	10:25		AW	Balance tank.		
13/5	12:25	14:00		AW	Routines + conf check taken		
14/5	06:45	06:50		WGL (End)	ABOLGO LAMP PMS ON 17		

This template is available on Hawk

Page 73 of 101

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions.

Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety

please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
14/5/25	8:45	10:30	[REDACTED]	AW	Balance tank valves. valves to be off.		
14/5/25	10:10	12:15	[REDACTED]	AW	Routines		
14/5/25	10:10	13:45	[REDACTED]	AW	MPX4 TURN-7 SET-UP.	←	
14/5/25	10:15	11:00	[REDACTED]	IOS	Deliver N ² flowmeters		
14/5/25	13:45	14:00	[REDACTED]	AW	FE MON		
14/5/25	14:45	15:20	[REDACTED]	AW	SITE VISIT		
15/5/25	6:40	7:10	[REDACTED]	WROR	1 X 28 5/2		
15/5/25	11:00	13:30	[REDACTED]	AW	Routines + alarms		
15/5/25	14:15	14:55	[REDACTED]	WROR	1 X 28 5/2		
16/5	07:40		[REDACTED]	AW	Plant meet setup + Routines		
16/5	07:44	15:15	[REDACTED]	WROR	Plant meet balance tank.		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
					40	0.57			
		SUNNY	/	VC	20	0.68	2.25	I	
MONITOR SET UP & READING OK - AGAINST ERIS			/	MF	20	0.87			
N/A		SUNNY	/	NA	NA	NA	N/A	N/A	N/A
		SUNNY	/	VC	20	2.21			
Both ground pits empty took from table									
		O-COAST	/	VC	30	1.54	2.16	I	
150N BT SMT: 10.5 BT error = 13.2 CASH I = 0.04		O-COAST	/	MF					
				VC	30	0.92	1.77	I	

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
16/5	08:15	11:00		AW	Site meet		
16/5	09:00	11:00		AW	Site visit		
16/5/25	09:45	11:00		AW	SITE VISIT		
16/5/25	09:30	10:30		AW	SITE VISIT		
16/5/25	11:25	11:35		DWS TA	PLC DFI Comm		
16/5	13:45	14:10		AW	Get HST sludge sample		
17/5	11:55	15:20		AW	HST belmows + Turbidity made log to lunch		
18/5	03:45	05:15		AW	High turbidity		
18/5/21	13:30	14:45		Whe	1x28m ² SK		
18/5/25	12:22	23:30		AW	Turbidity made log to + Cap Ave		
19/5/25	10:30	12:20		AW	Routines + Fe monitor		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

[illegible]

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
19/5	1100	14:40		Tivoli	Grounds		
19/5	1100	14:40		Tivoli	Grounds		
19/5	20:00	20:15		AW	fe solids mon		
20/5	09:20	11:10		AW	conf deck + routines + alarm		
20/5	0925	14:15		Tivoli	Grounds		
20/5	0925	14:15		Tivoli	Grounds		
20/5	13:30	14:05		SOS	spk chf.		
	13:30	14:05		AW	B/TANZ INSPECTION		
21/5	0530	0600		WREC	1x 28" s/R		
21/5/25	07:00	14:00			CLEAN PST x 4 SETTER.		
21/5	0735	09:30		AW	Routines + conf deck + alarm		

This template is available on Hawk

Page 79 of 101

Water Recycling Site Log Book Re-order Form

Site Details:

Site Name

Site Short Code

Re-order Date

This form should be completed and returned to the Local Ops Administrator, so that a new Water Recycling Site Log Book can be issued to the site

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant	
						Removed/Installed Details	Due Date for Return
21/5	13:30	14:00		AW	Photos of site		
22/5	07:30	09:55		AW	Routines + comp check + Fe chart		
22/5	12:00	12:40		AW	Fe monitor + lunch		
22/5	14:00	15:50		AW	EPP		
22.5	14:20	15:50		AW	EPP		
23/5/25	07:30	09:30		AW	Routines + comp check		
23/5/25	11:30	11:50		AW	Site check		
24/5/25	08:30	09:00		AW	Compliance check + Run Bellows		
24/5/25	09:30	11:00		AW	Instal Pacarcom Tank Run -		
25/5/25	06:05	06:55		WROZ	1 X 285K		
25/5/25	7:45	8:15		WROZ	1 X 285K		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
		Sunny	✓	VC ~~SC~~ MF 30	30	3.32			
	25	Sunny	✓	VC MF 30	30	0.74	1.23	I 1.79	
		Overcast	✓	SC MF 15	15	1.09			
ops on Standby Please check bellmouths on HSTs haven't stalled. Small trickle out of both needed to go returns.	23	Sunny	✓	SC/FF 10	10	0.64	0.64	I 0.51	12.7
Bellmouths on HSTs still tuning.	28	Sunny	✓	SC 45	45	0.59	0.79	I 0.66	13.9
Will need manual cleaning	31.46	Rain	✓	SC 5	5	0.76	0.73	Fe= 0.48	
groundwater not tested from TANWIC									

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant	
						Removed/Installed Details	Due Date for Return
25/5/15	09:35	10:40		AW	Routines + Run Bellmouths		
26/5/15	07:17	09:40		AW	Routines + met sedls + cc		
26/5/15	07:00	15:30		WROL	WORK RE DIRECTED	JETTER	
27/5	07:35	09:10		AW	conclock + Routines		
27/5	11:25	12:00		AW	check returns level + lunch		
27/5	20:05	20:30		AW	Turbidity monitor Alarm		
28/5	06:15	07:00		WROL	1828 ³ S/E		
28/5	09:30	12:45		M.GROUP	CALIBRATIONS		
29/5	12:50	15:30		AW	LUNCH + ROUTINES + ECO SURVEY + CC		
28.5.25	12:50	14:50		D.MACLEAN	ECO SURVEY		
28.5.25	12:50	14:50		D.MACLEAN	ECO SURVEY		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
HST2 bellmouth stalled & lowered and put it back up. Both flowing well. All BF arms played and stage holes cleared. Dosing fine PST1-3.0 PST2-3.0 PST3-2.8 PST4-3.0 HST5-2.1 before HST6.	30.5	Rain	/	SC	0	0.89	0.53	Fe- 0.25	
Packed	20.25	Sunny	/	FF SC	5	1.54	0.49	I- 0.42	
lower belmatus.	33	Sunny wet	/	FF	0	0.48	0.41	I- 0.29	
	36	wet	/	SC	10	0.73			
Cleaned monitor	32.44	overcast	/	SC	10	1.63	0.88	fe 0.99	
DOP-HST belmatus stalled and ok now	25	Rain	/	SC	5	1.54	0.61	I- 0.50	

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant	
						Removed/Installed Details	Due Date for Return
29/05/15	07:55	08:55		AW	Routines + Compliance Check		
29/05/15	11:45	12:30		AW	Site visit		
29/05/15	14:25	14:55		AW	Alarm - Computer		
30/5/15	6:40	8:40		AW	S.S.S		
30-5-25	19:30	20:00		WROC	1 x 28" S/R		
31-5-20	00:30	01:00		WROC	1 x 28" S/R		
31/8/25	9:00	10:00		AW	S.S.S		
1/6/25	9:30	10:30		AW	S.S.S		
16/05	18:20	19:00		AW	Inlet Fault + Turbidity Monitor		
2/6/25	08:00	8:45		AW	S.S.S		
2/6/25	10:10	10:45		AW	S.S.S		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples				FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify
PS11-3.1 PS12-3.1 PS13-3.0 PS14-3.1 HST1-2.2 HST2-2.3 Sludge 2% Sample probe cleared. Sparge holes cleared. Dosing after PF3 is fine. Bellmouths flowing well. Chloride > 500mg/l on crude. Test strips for Nitrate didn't appear to give readings which would be expected in Fe will renew with HACH test kit. Reset Compactor. Running. main Dissolved Chloride Dissolved Pools (PS) w/ w/ FLOW DONE Gravel Enclosed SHT 587.	22	Damp	/	CC	0	0.80	0.45	Fe = 0.24
	27	Dry	/	VC	5	1.40	0.75	Fe = 0.72
	28.	Dry	/	SC	0	0.64	0.39	VC = 0.21
	25			SC	0	0.43	0.44	VC = 0.26
	24			CC	0	0.39	0.53	VC = 0.17
Reset Screen - ANOK.	23	Sunny Dry	/	CC	0	3.28		
RODED FILTERS - RETURN ONES FOR NEW WOLF ROCKET	23	Dry		CC	0	0.91	0.51	VC = 0.36
Brown - PSI SLOW CAPS DEAT WITH								

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
2/6	15:00	17:00		Wipac	Sealant Compaction		
2/6/25	16:30	17:10		AW330	garage clear measurements		
3/6/25	08:30	10:00		AW330	garage clear		
03/06/25	10:35	11:35		AW	Compliance Check + Routines		
04/06	9:10	10:45		AW	Comp check + Routines		
5/6/25				AW	Balance Tank Renovation		
5/6/25	08:30	11:00		AW	Routines + cc + alarm		
5/6/25	12:30	13:00		Wipac	Trsp.		
6/6/25	07:35	08:40		AW	Routines + comp check		
6/6/25	14:15	15:00		AW	check sample		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
Boarded up garage door + rear windows									
HST-2 bellmouth stalled. Lowered it, desludged, put it back. All BFs rotating fine, stage valves closed.					S	0.38			
Both bellmouths flowing well. Cleared turbidity monitor. Dosing fine. All DTS are good.	2.8	Damp	✓	SC	0	0.73	0.73	Fe=	
Flushed both HST bellmouths + left cracked. Swept HSTs.								0.66	
Flushed filter arm, desludged balance tank + all PSTs.	30	Dry	✓	CC	S	0.55	0.43	Fe=	15.0
								0.32	
adjusted magnason dose rate, flush HST bellmouths									
Skim all WPSTs		wet	✓	CC	0	0.26	0.49	I=	
								0.28	
magnason turned off job parked to sample last job									
as per cm	22.3	wet	✓	SC	S	1.09	0.61	I=	
								0.49	
		Sunny	✓	VC	25	1.67	1.04	I=	
								1.21	

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
7/6/25	13:40	14:25	[REDACTED]	NLCL	1 x 28 5/2 C253769		
7/6/25	17:30	18:00		AWOS	CON-0 CHECK		
8/6/25	12:45	14:30		AWOS	ROUTING + COMP CHECK + SS MONITOR CLEAN		
9/6/25	07:50	10:00		AW	ROUTING + SAAP + COMP CHECK		
9/6/25	07:50	15:00	[REDACTED]	Que BB	3 x Bore holes		10/6
9/6/25	07:50	15:00		SI	SITE		10/6
9/6/25	7:50	15:00		SI	SITE		10/6
9/6/25	7:50	15:00		APHA	SITE		10/6
9/6/25	8:00	15:30	[REDACTED]	IOS	Site Setup for Flowmeter works		
9/6/25	09:30	10:30		AWOS	Audit.		
9/6/25	12:30			AW	DEWEE FE MONITOR FOR		

This template is available on Hawk
Template revision date: April 2014

Page 97 of 101

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
09/06/25	18:35	19:10	[REDACTED]	AW	Alarm - FE SS		
10/06/25	07:00	15:40	[REDACTED]	Que BB	3 x Bore holes		
10/06/25	07:30	15:40	[REDACTED]	ED	3 x Bore holes		
10/06/25	07:30	15:40	[REDACTED]	ED	3 x Bore holes		
10/06/25	07:30	15:40	[REDACTED]	ED	3 x Bore holes		
10/06/25	07:30	15:40	[REDACTED]	AW	comp check + ops		
10/06/25	09:00	09:30	[REDACTED]	IOS	Site Setup		
10/06/25	12:15	12:40	[REDACTED]	AW	Site Visit		
10/06/25	13:00	15:55	[REDACTED]	AW	SITG INSP		
10/06/25	14:15	15:55	[REDACTED]	AW	Site visit		
10/06/25	22:10	23:10	[REDACTED]	AW	FE holidays monitor		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
Dosing pump not running, magnesium not dosing. Bellmouths all good. Turned pump back on, dosing now. Cleaned SS sensor.	21	Dry	/	VC	30	2.07	1.18	Fe = 1.85	
Removed weed from SS sensor. Turned magnesium off after speaking to Full desudge Chem: 44% op, only 5% left.	20	overcast	✓	Sc	10	0.62	0.74	P I 0.59	15.7
Crude: nitrate 4mg/l. chloride. 250mg/l.			✓	S/C	10	0.90			
HST bellmouth was high & Humes Nelson was high, lifted both HST to ensure we stopping flow, were coming down. DM infrared checks for interesting. Samples to be done next day. Lamp checks to be run by DM	36.15	Dry	X	VC	20	1.85	1.02	Fe = 16.6	

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
11/6	07:35	07:40		AW	lower Delmarth		
11/6	07:40	16:50		APRA	site boreholes		
11/6	08:00	16:30		SI	—		
11/6	08:00	16:30		SI	—		
11/6	08:00	15:00		⑤ site standing	Site Borehole drilling		
11/6	08:45	10:50		AW	Routine S-SAA + earl deck		
11/6/15	10:55	15:30		AW	Re monitor		
12/6/15	07:55	08:55		AW	earl deck + Routine + Fernon		
12/6/15	07:56	14:15		APRA	Site Borehole		
12-6-25	08:00	14:15		SI	—		
12-6-25	08:00	14:15		SI	—		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
Parked									
lower Belmonts, Sign x1P5t	30	SUNNY	✓	SC	20	1.11	1.02	I	
		SUNNY	/	SC	20	2.23		I	
reset ferric June 2. updated oct. with return in the PM to turn magnesium dosing off	30	SUNNY	/	SC	25	1.41	1.20	I	

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
12/6/25	14:20	15:30		AW	lunch + comp check		
13/6/25	07:30	09:10		AW	Routines + comp checks		
13/06/25	01:30	01:45		ALD	OSM		
13/06	18:40	20:00		AW	FE Turbidity Monitor		
13/06	18:45	20:00		AW	magneson check		
14/06	15:30	16:20		AW	Comp check + Run HST beneath		
14/06	16:15	17:00		AW	magneson		
15/06	12:30	13:00		AW	magneson + lunch		
15/06	18:00	18:30		AW	Comp check + Screen 1 fault		
16/6	07:30	10:30		AW	Routines + comp check		
16/6/25	20:45	21:15		AW	HIGH SP		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
magnasol dosing turned off, updated OCT and check for tomorrow magnasol delivery due today. updated OCT	26	SUNNY	/	VC	15	1.73	1.17	I 1.16	
	24	SUNNY	/	VC	25	1.54	1.28	I 1.42	
Magnasol dosing again. Re Sample taken for bahn (16.8)	28	Warm	/	VC MF	20	1.44	1.36	FE 1.39	19.2
lowered bellmouths and raised back up - left cracked. Reset dosing P2. Magnasol topped up + still dosing.	25	Warm	/	MF	18	1.51	1.30	FE 0.88	19.8
Topped up tank added SBL. Return tomorrow to re-top up to get through to Monday site secure									
SBL top up with grab SOL move to continue with with till tomorrow									
Reset Screen.	23	Dry	/	MF	20	2.20	1.42	FE 1.19	17.9
	19	SUNNY	/	VC	15	1.04	1.02	I 1.16	
CLEANED WEST OF OF SEWSON	22	/	/	SC	10	1.22	1.18	1.43	18.1

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant Removed/Installed	
						Details	Due Date for Return
17/6	07:35	09:10		AW	Patrol + check + alarms		
17/6	10:00	10:15		AW	To get measurements off Fe Sampling box		
18/6/25	18:55	19:30		AW	SOUND monitor		
18/6/25	07:30	10:40		AW	Routines		
18.6.25	08:50	10:45		AW	EA TEST		
18.6.25	09:19	10:45		EA	OSM Compliance visit		
18/06/25	09:23	10:00		AW	Set up 3 x auto samplers for P Scheme. Set + Comp on Grade Comp - FE. NOT Completed		
"	09:40			EA	OSM Compliance.		
18/06/25	10:15	11:00		AW	Dosing Pump tripped.		
18/06/25	21:22	22:40		AW	Turbidity monitor Fe		
19/06/25	01:13	01:25		AW	Winding up Sampling kit		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify	
	19.26	SUNNY warm	/	VC	10	1.64	1.36	I	
CONCRETE SITE USED OFF	23.01	DRY SUNNY	/	VC	10	1.23	1.36	1.38	
	20.14	SUNNY warm	/	VC	15	1.17	1.40	I	
check pipework, reset dosing as shown.		Work, 25°C	/						
	27.15	DS	X	VC	15	1.88	1.32	1.18	18.6
		DS	X	VC	15	2.04	1.32	0.92	18.6

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Date In	Time In	Time Out	Name	Company	Reason for Visit	Equipment & Plant	
						Removed/Installed Details	Due Date for Return
19/6/25	6:58			BIOMARSH	C253 663		
19/6	7:30	D/S		BIOMARSH	C253 352		
19/6	08:30	15:30		AW	Routines		
19/06	20:30	24:20		AW	FE Turbidity Monitor		
19/6/25	19:00	21:20		AW	Chemical Dosing		
20/06/25	16:40	DAY SHIFT		BIOMARSH	C253 671		
20/6	07:30	14:15		AW	Routines + cc + alarm + assist		
20/6/25	20:15	20:45		AW	Solids monitor		
21/6/25	5:00	5:30		WROZ	1x2832		
21/6/25	09:45	10:45		AW	Comp check & run HST, beam mouths, FE Solids monitor		
22/6/25	5:00	5:30		WROZ	1x2832		

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples				FE Temp °C
				Visual Check	SS	NH ₃	P	Other Specify
Cleaned Probe		Sunny Hot	✓	VC	15	1.07	1.58	0.58 I
cleaned out flow assembly		Warm	✓	VC	25	1.92	1.95	Fe 0.89
		h-	✓					
	20	Sunny Hot	✓	VC	15	1.25	1.56	I 0.94
Removed weeds.		DRY	✓	VC	25	1.43	2.40 1.13	I 1.13
Removed weeds. Desludged, bellmouths lifted back up and bricking out.	24	DRY	✓	VC	15	0.74	2.04	I 0.84

